

State Water Resources Control Board

October 29, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5833

Mr. Mel Laningham
Fleet Superintendent
Kings County
1400 West Lacey Boulevard
Hanford, California 93230
mel.laningham@co.kings.ca.us

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT KINGS COUNTY MOTOR POOL, 1400 WEST LACEY
BOULEVARD, HANFORD**

Dear Mr. Laningham:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on October 18, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Monitor Product Piping – The sensor in the under-dispenser containment #2 is incorrectly positioned at an angle.	Unleaded	October 18, 2018	Ongoing	23 CCR 2630(d)
2	Failure to Maintain Financial Responsibility – The Chief Financial Officer letter is dated March 14, 2017; this letter is required to be updated every 12 months.	Unleaded	March 15, 2018	Ongoing	23 CCR 2711(a)(11)
3	Failure to Maintain Site Map – The site map in CERS does not show the location of sensors or piping.	Unleaded	October 18, 2018	Ongoing	23 CCR 2632(d)(1)(C), 2711(a)(8)

No.	Violation	Tank	Start Date	Stop Date	Regulation
4	Failure to Maintain Primary Containment – Product was observed dripping into the under-dispenser containment from inside the dispenser.	Unleaded	October 18, 2018	Ongoing	H&SC 25291(a)(1); 23 CCR 2631(a)
5	Failure to Meet Under-Dispenser Containment (UDC) Requirements – The UDC #1 and #2 are smaller than the dispenser footprint and are not able to provide secondary containment for piping within the dispenser.	Unleaded	October 18, 2018	Ongoing	23 CCR 2636(g)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Kings County Environmental Health within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov

Local CUPA

Mr. Lee Johnson
Supervising Environmental Health Officer
Kings County Environmental Health
330 Campus Drive
Hanford, California 93230
lee.johnson@co.kings.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at matthew.buffleben@waterboards.ca.gov.

Sincerely,



Matthew Buffleben
Supervising Water Resources Control Engineer
Acting Supervisor, UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Mr. Lee Johnson
Supervising Environmental Health Officer
Kings County Environmental Health
lee.johnson@co.kings.ca.us

Mr. Luis Flores
Environmental Health Officer IV
Kings County Environmental Health
luis.flores@co.kings.ca.us

Mr. Kipp Cox
Service Writer
Kings County
kipp.cox@co.kings.ca.us